



Certificate of Compliance

Certificate: 1559194

Master Contract: 211308

Project: 2362564

Date Issued: October 28, 2010

Issued to: PT. Ever Age Valves Metals

J1 Raya Sumengko KM 30.7
Wringinanom
Gresik
Jatim, 61176
Indonesia
Attention: Gatot Harry

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



James Sekerak

Issued by: James Sekerak

PRODUCTS

CLASS 3371 88 - VALVES (GAS) - General Use-Certified to U.S. Standards

CLASS 3371 08 - VALVES (GAS) - General Use

3371-08 VALVES (GAS) - General Use

For Use with Natural and Propane Gases

For operation at ambient temperatures of 32°F to 125°F

Trademark: E. A. (Ever Age)

Straight



Certificate: 1559194

Master Contract: 211308

Project: 2362564

Date Issued: October 28, 2010

Model Number

- SVS, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)
- BVL 2S, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)
- BVL 3S, Rated Pressure: ½ psig; Size: ¾” NPT (F) x ¾” NPT (F)
- BVG 2, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)
- BVG 3, Rated Pressure: ½ psig; Size: ¾” NPT (F) x ¾” NPT (F)
- BVG 4, Rated Pressure: ½ psig; Size: 1” NPT (F) x 1” NPT (F)
- BVG 21R, Rated Pressure: ½ psig; Size: ½” NPT (F) x 1/4fl.
- BVG 22, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (M)
- BVG 22R, Rated Pressure: ½ psig; Size: ½” NPT (F) x 3/8fl.
- BVG 32R, Rated Pressure: ½ psig; Size: ¾” NPT (F) x 3/8fl.
- BVG 33, Rated Pressure: ½ psig; Size: ¾” NPT (F) x ¾” NPT (M)
- BVG 44, Rated Pressure: ½ psig; Size: 1” NPT (F) x 1” NPT (M)
- BVG 315R, Rated Pressure: ½ psig; Size: ¾” NPT (F) x 1/2fl.

Angle

Model Number

- SVL, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)
- BVL 2L, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)
- BVL 3L, Rated Pressure: ½ psig; Size: ¾” NPT (F) x ¾” NPT (F)

3371-88 VALVES (GAS) – General Use-Certified to U.S. Standards



Certificate: 1559194

Master Contract: 211308

Project: 2362564

Date Issued: October 28, 2010

For Use With Natural, Mfd, Mixed, Liquefied Petroleum and LP Gas-Air Mixtures

For operation at ambient temperatures of 32°F to 125°F

Trademark: E. A. (Ever Age)

Straight

Model Number

SVS, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)

BVL 2S, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)

BVL 3S, Rated Pressure: ½ psig; Size: ¾” NPT (F) x ¾” NPT (F)

BVG 2, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)

BVG 3, Rated Pressure: ½ psig; Size: ¾” NPT (F) x ¾” NPT (F)

BVG 4, Rated Pressure: ½ psig; Size: 1” NPT (F) x 1” NPT (F)

BVG 21R, Rated Pressure: ½ psig; Size: ½” NPT (F) x 1/4fl.

BVG 22, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (M)

BVG 22R, Rated Pressure: ½ psig; Size: ½” NPT (F) x 3/8fl.

BVG 32R, Rated Pressure: ½ psig; Size: ¾” NPT (F) x 3/8fl.

BVG 33, Rated Pressure: ½ psig; Size: ¾” NPT (F) x ¾” NPT (M)

BVG 44, Rated Pressure: ½ psig; Size: 1” NPT (F) x 1” NPT (M)

BVG 315R, Rated Pressure: ½ psig; Size: ¾” NPT (F) x 1/2fl.

Angle



Certificate: 1559194

Master Contract: 211308

Project: 2362564

Date Issued: October 28, 2010

Model Number

SVL, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)

BVL 2L, Rated Pressure: ½ psig; Size: ½” NPT (F) x ½” NPT (F)

BVL 3L, Rated Pressure: ½ psig; Size: ¾” NPT (F) x ¾” NPT (F)

APPLICABLE REQUIREMENTS

ANSI Z21.15-2009/CSA 9.1-2009 - Manually Operated Gas Valves for Appliances, Appliance Connector Valves and Hose End Valves

MARKINGS

Markings shall be permanent. All models shall indicate the following markings:

- The manufacturer’s Name or trademark - E. A. (Ever Age) (shall be cast on the body),
- Date-code (shall be cast on the body)
- “1/2 psi”, (shall be cast on the body)
- Certification Marking – “CSA Monogram with “C” and “US” indicators.